

# Rental Property Requirements

## Approved Carbon Monoxide Alarms

(1) A single or multiple station carbon monoxide alarm listed as complying with the Approved American National Standard for Single and Multiple Station Carbon Monoxide Alarms (ANSI/UL2034) or a carbon monoxide detector listed as complying with the Approved American National Standard for Gas and Vapor Detectors and Sensors (ANSI/UL2075) installed in accordance with this act.

(2) A device that may be combined with a smoke alarm or smoke detector if the combined smoke alarm or detector meets all of the following:

(i) Complies with either of the following:

(A) The Approved American National Standard for Single and Multiple Station Carbon Monoxide Alarms (ANSI/UL2034) for carbon monoxide alarms and the Approved American National Standard for Single and Multiple Station Smoke Alarms (ANSI/UL217) for smoke alarms.

(B) The Approved American National Standard for Gas and Vapor Detectors and Sensors (ANSI/UL2075) for carbon monoxide detectors and the Approved American National Standard for Safety for Smoke Detectors for Fire Alarm Systems (ANSI/UL268) for smoke detectors.

(ii) Emits an alarm in a manner that clearly differentiates between detecting the presence of carbon monoxide and the presence of smoke.

(3) A carbon monoxide detection system that includes carbon monoxide detectors and audible notification appliances that are installed and maintained in accordance with the National Fire Alarm and Signaling Code (NFPA 72) and the Standard for the Installation of Carbon Monoxide (CO) Detection and Warning Equipment (NFPA 720) and are in compliance with the Approved American National Standard for Gas and Vapor Detectors and Sensors (ANSI/UL2075).